



**Cable ID: SAMPLE**

Date / Time: 2020-01-01 12:34:56 PM

Headroom 2.6 dB (NEXT 3,6-4,5)

Test Limit: TIA 568.2-D Patch Cord Cat6A 0.5m

Cable Type: Cat 6A U/FTP

NVP: 74.0%

Operator: CJJ

Software Version: V6.0 Build 6

Limits Version: V7.0

Calibration Start Date:

Main (Module): 2018-06-03

Remote (Module): 2018-06-03

**Test Summary: PASS**

Model: DSX-5000


Main S/N: 18060497

Remote S/N: 18060417



Main Adapter: DSX-PC6A

Remote Adapter: DSX-PC6A

Wire Map	1	2	3	4	5	6	7	8	S
<b>PASS</b>									
(T568B)	1	2	3	4	5	6	7	8	S





Length (m)	[Pair 1,2]	0.2
Prop. Delay (ns)	[Pair 4,5]	1
Delay Skew (ns)	[Pair 1,2]	0
Resistance (ohms)	[Pair 4,5]	0.14



Worst Case Margin Worst Case Value

PASS	MAIN	SR	MAIN	SR
Worst Pair	3,6-4,5	3,6-4,5	3,6-4,5	3,6-7,8
<b>NEXT (dB)</b>	2.7	2.6	5.9	5.0
Freq. (MHz)	282.0	252.0	500.0	500.0
Limit (dB)	36.7	38.1	29.5	30.9



PASS	MAIN	SR	MAIN	SR
Worst Pair	3,6	4,5	1,2	7,8
<b>RL (dB)</b>	2.6	2.8	4.2	4.7
Freq. (MHz)	121.0	145.0	416.0	500.0
Limit (dB)	17.2	16.4	10.7	9.5

SAMPLE